

MODEL		LGH-65RVX3-E				SIGN	
Heat exchange system		Energy recovery ventilating system					
Heat exchanger (Lossnay core)		Special treated paper plate heat exchanger					
Cladding		Galvanized steel sheet					
Motor		EC motor					
Filter		Non-woven fabrics filter (ISO 16890 Coarse 60%)					
Surrounding air condition		0°C to 40 °C, 80%RH or less					
Suction air condition		Lower than 40°C, 80%RH.					
Supply fan operation under low outdoor temperature		-10°C to -15°C : Intermittent operation 60 min ON, 10 min OFF -15°C or less : Sensing operation 55 min OFF, 5 min ON					
Weight		41kg					
Electrical power supply		220-240V/50Hz, 220V/60Hz					
Fan speed		4	3	2	1	Test condition	
Default Airflow setting		100%	75%	50%	25%		
Input power [W]		245	120	51	20	EN13053: 2019	
Airflow	[m³/h]	650	488	325	163		
	[L/s]	181	135	90	45		
Specific fan power [W/(L/s)]		1.36	0.89	0.56	0.44		
External static pressure [Pa]		150	85	38	10	EN308: 2022	
Temp. exchange efficiency [%]	Heating	72.5	75.0	78.5	82.0		
	Cooling	65.0	70.0	74.5	80.0		
Enthalpy exchange efficiency [%]	Heating	69.5	72.0	76.5	80.0		
	Cooling	50.5	55.0	61.5	69.0		
Noise [dB]		37.5	31.5	24.0	17.5	A-weighted sound pressure level	
Exhaust Air Transfer Ratio [%]		5.0				EN308: 2022 / FS3	
External leakage [%]		5.0				EN1886: 2007/ Nominal flow rate	
Insulation resistance		10MΩ or more					
Dielectric strength		AC 1000V 1 minute					
Maximum current [A]		2.37					

■ Attention

1. The input power, the efficiency and the noise are based on the rating air volume, 230V/50Hz and horizontal installation. Noise (A-weighted sound pressure level) is measured 1.5m off from the center of the unit in an anechoic chamber.
2. Heat recovery ventilation mode starts automatically while detecting OA temperature lower than 8°C, even Bypass mode is selected. Remote controller continues to display "Bypass ventilation" in this case.
3. Do not use the booster fan to exceed airflow rate/pressure shown in Q-H diagram of the unit.
4. It is prohibited to use the unit where salt, sulphur or hot spring steam damage is expected.
5. Do not use with acid, alkalis, organic solvent, oil mist, paint, or harmful gas as pesticide, corrosive gas, etc.
6. In cold area or strong wind area, outdoor air may enter the unit because of the pressure difference or external wind even when the unit stops. It is recommended to install an electrically damper to block outdoor air in such cases.
7. Avoid to install air inlets and outlets where insects are likely to gather like a place near interior or exterior lights. In that case, select hoods or louvers which have repellent net.

※Specifications may be subject to change without notice.

SPECIFICATIONS	DATE	TYPE MODEL	CEILING RECESSED LOSSNAY	
	25-Jan-23		LGH-65RVX3-E	
MITSUBISHI ELECTRIC CORPORATION		NUMBER	N22HHGU0005	1/4